

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Halstead

29 Oakwood Avenue, Norwalk, CT, United States

For the following product(s):

## Vinyl Tile:

Allure 5mm (Ultra), *Added 2/17/21*: Allure Contact, Home Decorators Collection - LVT Clic and Solid Polymer Core (SPC), Lifeproof, Stayplace, Trafficmaster/Allure Plank & Tile, Verge, Verge Pro

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-02874

Valid from: December 1, 2020 to November 30, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION  
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President

SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA